

Water Quality Lab Report

Prepared For:
Jeffrey Smith

ORDER

Kit Type: Safe Home® LEAD
Order Number: 2024120047
Report Date: 12.20.24
Notes:

SAMPLE

Sample Collected: 12.05.24
Sample Received: 12.16.24

Analysis performed by our EPA-certified laboratory: Environmental Laboratories, Inc., Madison, IN 47250
Certification Numbers: M-39-01, C-39-01

Report Key

This page is intended to help you gain clarity about the contents of your lab report. If you have further questions beyond the scope of this report, please contact us and one of our drinking water specialists will gladly assist you.

REPORT TERMINOLOGY & DEFINITIONS

Parameter: *Specific element, compound, or condition being measured.*

Instrument Limit: *Lowest level of a parameter our instrument can detect (Method Detection Limit).*

***EPA Limit:** *Highest level of a parameter allowable by US-EPA standards.*






mg/L: *Unit of measurement used to describe how many milligrams of a parameter is present in every liter of your water - also referred to as parts per million (ppm).*

ND: *Parameter was not detected in your water sample.*

Parameter Effect: *Illustrates possible effects to your Health, House, or the Aesthetics of your water.*

--: *No EPA limit or acceptable range associated with the parameter.*

LAB RESULT QUALIFIERS

-  **Good:** *Not detected in your water sample, or the measurement falls within EPA acceptable range.*
-  **Fair:** *Concentration is less than half of the EPA limit, if there is a limit listed. If no EPA limit is listed, yellow indicates that we simply detected the parameter in your sample.*
-  **Poor:** *Concentration is greater than half of EPA limit.*
-  **Bad:** *Over EPA limit, or the measurement falls outside of EPA acceptable range.*
-  **Fail:** *Your in-lab bacteria sample (not DIY) arrived at our lab more than 24hrs after collection.*

PARAMETER EFFECTS



Aesthetics: *Concentrations considered higher, or out of range, may affect taste, smell or visual appearance of your water.*



Appliances: *Concentrations considered higher, or out of range, may adversely affect your appliances, plumbing fixtures, etc.*



Health: *Concentrations considered higher, or out of range, may adversely affect your health.*


* EPA limits are established for public utilities and treated water supplies. These standards may be referred to as Action Levels, Maximum Contaminant Levels or Acceptable Ranges. Such standards are also valuable for owners of well water supplies.

Note: Test results within EPA standards do not guarantee the safety of your water supply. Example - Lead has an Action Level of 0.015 ppm. However, no level of Lead is safe to consume. Please refer to the following link to learn more about EPA drinking water standards <https://www.epa.gov/dwreginfo/drinking-water-regulations>.

Test Results

Metals

Sample ID: P1224-80 **Sample Location:** YELLOW - kitchen sink

Parameter	Instrument Limit	Your Water	EPA Limit	Units	Effect
Lead	0.0010	● ND	0.015	mg/L	

Sample ID: P1224-81 **Sample Location:** RED - kitchen sink

Parameter	Instrument Limit	Your Water	EPA Limit	Units	Effect
Lead	0.0010	● ND	0.015	mg/L	